



Sure Controls
N981 Tower View Drive
Greenville, WI 54942

CERTIFICATE OF CALIBRATION

Unit Model #: 195374
Unit Serial #: MB430147G
Recorder Serial #: PL1142000584-4211-PL3
Instrument #: 128506
MAC Address: 00:0A:8D:01:F5:FA

Sure Controls does hereby certify the above instrument was calibrated against standards maintained by Sure Controls and meets or exceeds all published specifications. The accuracy of these standards is directly traceable to the National Institute of Standards and Technology.

Recorder	Displayed Value		
	Primary Standard Signal 382.0 ° F	Primary Standard Signal 882.0° F	Primary Standard Signal 1382.0° F
CHANNEL 1	382	882	1382
CHANNEL 2	382	882	1383
CHANNEL 3	382	882	1383
CHANNEL 4	382	882	1383
CHANNEL 5	382	882	1382
CHANNEL 6	382	882	1383

Calibration Date: 11/8/2011

Recalibration Date: 11/8/2012

Certified by: CMP

Instrumentation Used: Beamex Model No. MC5 Multi-Function Calibrator
Beamex Serial No. 25513615MJP
Sure Controls ID No. STD-035